



## NOTES

1. MANHOLE REQUIRED WHERE LATERAL PIPE OR CONNECTING PIPE EXCEEDS 1/2 MAIN PIPE DIAMETER.
- ② LATERAL PIPE SHALL NOT EXTEND INTO THE CROSS SECTION OF MAIN PIPE BEYOND THAT REQUIRED FOR FULL WALL SUPPORT.

|  |                         |                                   |           |
|--|-------------------------|-----------------------------------|-----------|
| DEPARTMENT OF PUBLIC WORKS<br>CITY OF ROCHESTER, MINNESOTA   |                         |                                   |           |
| <b>BLIND-TIE FIELD CONNECTION<br/>FOR R.C.P. STORM SEWER</b> |                         |                                   |           |
| <i>Donald Nelson</i><br>ASST. CITY ENGINEER                  |                         | <i>Paul W. Finner</i><br>DIRECTOR |           |
| SHT 1 OF 1 SHTS  | DATE REVISED<br>3/22/06 | PLATE NO.<br>1-13                 | REV.<br>B |